

Fr. Křížka 461/11, Praha 7

Tabulka čerpadel

	Okruhy	Potrubí						
		Q (kW)	DN	Spád (°C)	dt (°C)	m (kg/hod)	dp o. (kPa)	TYP
	Kotlové	120,0	50	75/60	15	6879	10+3	MAGNA3 50-40 F
G	Byty	135,0	70	75/59	16,2	7165	30+5	MAGNA3 D 50-60 F
					TSV		DN 50	Kv = 40
F	Spoj. Krček	13,0	25	75/55	20	559	10+5	ALPHA2 25-40
					TSV		DN 15	Kv = 4
E	Tělesa PIM	61,0	50	75/60	15	3497	23+5	MAGNA3 40-80 F
					TSV		DN 32	Kv = 16
D	Klima PIM	58,0	40	75/55	20	2494		25 MAGNA3 32-120 F
C	VZT PIM	57,0	40	75/55	20	2451	11+3	MAGNA3 32-120 F
B	TUV PIM	39	32	75/50	15	2236		30 MAGNA3 32-120 F
A	TUV byty	123	50	75/50	15	7051		35 MAGNA3 32-120 F
	Vodní obsah					Výška systému		27 m
	kotle	48				Nejnižší prac. Přetlak		300 kPa
	byty	2464				Nejvyšší prac. Přetlak		350 kPa
	klub	450						
	tMarth	732						
	FC Mar	290						
	VZT Marath	50						
	stroj	200						
		4234						