

Mistnost				tepelne ztraty			vymena vzduchu		
cislo	teplota	plocha	objem	prostupem	infiltr.	hyg.	celkem	infiltr.	vetr.
-	ti	S	V	Qp	QvP	QvH	Qc	nP	nH
-	oC	m2	m3	W	W	W	W	1/hod	1/hod

1. podzemni podlazi									

1	20	46.0	128.8	4980	463	0	5443	0.31	0.00
0	7	22.8	63.7	813	133	0	946	0.30	0.00
Soucet		68.8	192.5	5793	596	0	6389		

1. podlazi									

101	20	24.8	70.5	3046	393	0	3439	0.48	0.00
102	20	2.0	5.7	808	80	0	888	1.22	! 0.00
201	20	24.8	70.5	3440	399	0	3839	0.49	0.00
202	24	2.0	5.7	869	90	0	960	1.22	! 0.00
203	20	11.2	32.1	2717	279	0	2997	0.75	! 0.00
Soucet		64.8	184.5	10880	1242	0	12123		

Mistnost				tepelne ztraty			vymena vzduchu		
cislo	teplota	plocha	objem	prostupem	infiltr.	hyg.	celkem	infiltr.	vetr.
-	ti	S	V	Qp	QvP	QvH	Qc	nP	nH
-	oC	m2	m3	W	W	W	W	1/hod	1/hod

3. podlazi

3401	20	5.6	16.0	1040	409	0	1450	2.22	!	0.00
3402	20	17.3	49.2	1813	433	0	2246	0.76	!	0.00
3403	20	22.8	65.0	930	423	0	1353	0.56	!	0.00
3404	24	2.9	8.2	433	0	0	433	0.00		0.00
3407	18	9.9	28.2	123	0	0	123	0.00		0.00
3105	20	20.7	58.9	820	435	0	1255	0.64	!	0.00
3104	24	3.9	11.1	368	0	0	368	0.00		0.00
3106	20	21.6	61.6	1017	423	0	1440	0.59	!	0.00
3109	18	19.6	55.9	286	0	0	286	0.00		0.00
3107	20	22.0	62.7	1487	885	0	2372	1.22	!	0.00
3108	20	21.3	60.6	755	433	0	1188	0.62	!	0.00
3202	20	25.1	71.5	1037	423	0	1460	0.51	!	0.00
3201	18	10.0	28.5	73	0	0	73	0.00		0.00
3203	20	20.4	58.1	832	435	0	1266	0.65	!	0.00
3205	24	4.6	13.1	658	0	0	658	0.00		0.00
3204	20	22.8	65.0	895	423	0	1318	0.56	!	0.00
3302	24	4.6	13.1	267	0	0	267	0.00		0.00
3304	20	40.0	114.0	1086	433	0	1519	0.33		0.00
3301	18	8.0	22.8	73	0	0	73	0.00		0.00
3305	20	27.2	77.5	1144	364	0	1508	0.41		0.00
3306	20	3.6	10.3	931	149	0	1081	1.26	!	0.00
3308	20	13.2	37.8	1076	373	0	1449	0.86	!	0.00
Soucet		347.1	989.1	17147	6040	0	23188			

Mistnost				tepelne ztraty			vymena vzduchu		
cislo	teplota	plocha	objem	prostupem	infiltr.	hyg.	celkem	infiltr.	vetr.
-	ti	S	V	Qp	QvP	QvH	Qc	nP	nH
-	oC	m2	m3	W	W	W	W	1/hod	1/hod

4. podlazi

4401	20	5.6	16.0	1002	409	0	1412	2.22	!	0.00
4402	20	17.3	49.2	1719	433	0	2151	0.76	!	0.00
4403	20	22.8	65.0	790	423	0	1213	0.56	!	0.00
4404	24	2.9	8.2	401	0	0	401	0.00		0.00
4407	18	9.9	28.2	90	0	0	90	0.00		0.00
4104	24	3.9	11.1	326	0	0	326	0.00		0.00
4105	20	20.7	58.9	694	435	0	1129	0.64	!	0.00
4106	20	21.6	61.6	883	423	0	1306	0.59	!	0.00
4107	20	22.0	62.7	1352	885	0	2237	1.22	!	0.00
4108	20	21.3	60.6	637	433	0	1069	0.62	!	0.00
4109	18	19.6	55.9	220	0	0	220	0.00		0.00
4202	20	25.1	71.5	895	423	0	1318	0.51	!	0.00
4203	20	20.4	58.1	717	435	0	1152	0.65	!	0.00
4201	18	10.0	28.5	40	0	0	40	0.00		0.00
4205	24	4.6	13.1	607	0	0	607	0.00		0.00
4204	20	22.8	65.0	767	423	0	1190	0.56	!	0.00
4302	24	4.6	13.1	219	0	0	219	0.00		0.00
4304	20	40.0	114.0	865	433	0	1298	0.33		0.00
4305	20	27.2	77.5	969	364	0	1333	0.41		0.00
4306	20	3.6	10.3	905	149	0	1055	1.26	!	0.00
4308	20	13.2	37.8	988	373	0	1362	0.86	!	0.00
4301	18	8.0	22.8	46	0	0	46	0.00		0.00
Soucet		347.1	989.1	15134	6040	0	21174			

cislo	Mistnost			tepelne ztraty			celkem	vymena vzduchu	
	teplota	plocha	objem	prostupem	infiltr.	hyg.		infiltr.	vetr.
	ti oC	S m2	V m3	Qp W	QvP W	QvH W		nP 1/hod	nH 1/hod

5. podlazi

5401	20	5.6	16.0	1002	246	0	1248	1.33 !	0.00
5402	20	17.3	49.2	1719	260	0	1978	0.46	0.00
5403	20	22.8	65.0	790	254	0	1044	0.34	0.00
5404	24	2.9	8.2	401	0	0	401	0.00	0.00
5407	18	9.9	28.2	90	0	0	90	0.00	0.00
5104	24	3.9	11.1	326	0	0	326	0.00	0.00
5105	20	20.7	58.9	694	261	0	955	0.38	0.00
5106	20	21.6	61.6	883	254	0	1137	0.36	0.00
5107	20	22.0	62.7	1352	531	0	1883	0.73 !	0.00
5108	20	21.3	60.6	637	260	0	896	0.37	0.00
5109	18	19.6	55.9	220	0	0	220	0.00	0.00
5202	20	25.1	71.5	895	254	0	1149	0.31	0.00
5201	18	10.0	28.5	40	0	0	40	0.00	0.00
5205	24	4.6	13.1	607	0	0	607	0.00	0.00
5203	20	20.4	58.1	717	261	0	978	0.39	0.00
5204	20	22.8	65.0	767	254	0	1021	0.34	0.00
5302	24	4.6	13.1	219	0	0	219	0.00	0.00
5304	20	40.0	114.0	865	260	0	1125	0.20	0.00
5301	18	8.0	22.8	46	0	0	46	0.00	0.00
5305	20	27.2	77.5	969	218	0	1188	0.24	0.00
5306	20	3.6	10.3	905	90	0	995	0.76 !	0.00
5308	20	13.2	37.8	988	224	0	1212	0.51 !	0.00
Soucet		347.1	989.1	15134	3624	0	18758		

Mistnost				tepelne ztraty			vymena vzduchu		
cislo	teplota	plocha	objem	prostupem	infiltr.	hyg.	celkem	infiltr.	vetr.
-	ti	S	V	Qp	QvP	QvH	Qc	nP	nH
-	oC	m2	m3	W	W	W	W	1/hod	1/hod

6. podlazi

6401	20	5.6	16.0	1002	246	0	1248	1.33 !	0.00
6402	20	17.3	49.2	1719	260	0	1978	0.46	0.00
6403	20	22.8	65.0	790	254	0	1044	0.34	0.00
6404	24	2.9	8.2	401	0	0	401	0.00	0.00
6407	18	9.9	28.2	90	0	0	90	0.00	0.00
6104	24	3.9	11.1	326	0	0	326	0.00	0.00
6105	20	20.7	58.9	694	261	0	955	0.38	0.00
6106	20	21.6	61.6	883	254	0	1137	0.36	0.00
6107	20	22.0	62.7	1352	531	0	1883	0.73 !	0.00
6108	20	21.3	60.6	637	260	0	896	0.37	0.00
6109	18	19.6	55.9	220	0	0	220	0.00	0.00
6202	20	25.1	71.5	895	254	0	1149	0.31	0.00
6203	20	20.4	58.1	717	261	0	978	0.39	0.00
6205	24	4.6	13.1	607	0	0	607	0.00	0.00
6201	18	10.0	28.5	40	0	0	40	0.00	0.00
6204	20	22.8	65.0	767	254	0	1021	0.34	0.00
6304	20	40.0	114.0	865	260	0	1125	0.20	0.00
6302	24	4.6	13.1	219	0	0	219	0.00	0.00
6301	18	8.0	22.8	46	0	0	46	0.00	0.00
6305	20	27.2	77.5	969	218	0	1188	0.24	0.00
6306	20	3.6	10.3	905	90	0	995	0.76 !	0.00
6308	20	13.2	37.8	988	224	0	1212	0.51 !	0.00
Soucet		347.1	989.1	15134	3624	0	18758		

Mistnost				tepelne ztraty			vymena vzduchu		
cislo	teplota	plocha	objem	prostupem	infiltr.	hyg.	celkem	infiltr.	vetr.
-	ti	S	V	Qp	QvP	QvH	Qc	nP	nH
-	oC	m2	m3	W	W	W	W	1/hod	1/hod

7. podlazi

7401	20	5.6	16.0	1182	246	0	1427	1.33 !	0.00
7402	20	17.3	49.2	2263	260	0	2522	0.46	0.00
7403	20	22.8	65.0	1136	254	0	1389	0.34	0.00
7404	24	2.9	8.2	401	0	0	401	0.00	0.00
7407	18	9.9	28.2	90	0	0	90	0.00	0.00
7104	24	3.9	11.1	326	0	0	326	0.00	0.00
7105	20	20.7	58.9	1039	261	0	1299	0.38	0.00
7106	20	21.6	61.6	1232	254	0	1485	0.36	0.00
7107	20	22.0	62.7	1963	531	0	2494	0.73 !	0.00
7108	20	21.3	60.6	951	260	0	1210	0.37	0.00
7109	18	19.6	55.9	220	0	0	220	0.00	0.00
7202	20	25.1	71.5	1213	254	0	1466	0.31	0.00
7203	20	20.4	58.1	1034	261	0	1295	0.39	0.00
7205	24	4.6	13.1	607	0	0	607	0.00	0.00
7201	18	10.0	28.5	40	0	0	40	0.00	0.00
7204	20	22.8	65.0	1083	254	0	1337	0.34	0.00
7302	24	4.6	13.1	219	0	0	219	0.00	0.00
7304	20	40.0	114.0	1071	260	0	1331	0.20	0.00
7301	18	8.0	22.8	46	0	0	46	0.00	0.00
7305	20	27.2	77.5	1209	218	0	1427	0.24	0.00
7306	20	3.6	10.3	1028	90	0	1117	0.76 !	0.00
7308	20	13.2	37.8	988	224	0	1212	0.51 !	0.00

Soucet		347.1	989.1	19339	3624	0	22963		
--------	--	-------	-------	-------	------	---	-------	--	--

Mistnost				tepelne ztraty			vymena vzduchu		
cislo	teplota	plocha	objem	prostupem	infiltr.	hyg.	celkem	infiltr.	vetr.
-	ti	S	V	Qp	QvP	QvH	Qc	nP	nH
-	oC	m2	m3	W	W	W	W	1/hod	1/hod

8. podlazi

8401	20	9.0	21.6	1065	149	0	1214	0.60	!	0.00
8402	20	5.0	12.0	1181	73	0	1254	0.53	!	0.00
8403	20	11.4	27.4	950	257	0	1207	0.81	!	0.00
8404	24	2.9	6.9	570	0	0	570	0.00		0.00
8101	18	18.0	43.2	375	0	0	375	0.00		0.00
8102	24	4.5	10.8	1084	0	0	1084	0.00		0.00
8103	20	1.4	3.5	116	0	0	116	0.00		0.00
8104	20	19.2	46.2	1228	249	0	1477	0.47		0.00
8105	20	39.0	93.6	3487	331	0	3818	0.31		0.00
8202	20	12.9	31.1	936	236	0	1172	0.66	!	0.00
8203	20	14.0	33.6	1022	236	0	1258	0.61	!	0.00
8201	18	5.1	12.2	172	0	0	172	0.00		0.00
8204	24	3.0	7.2	794	0	0	794	0.00		0.00
8303	20	26.2	63.0	1869	331	0	2200	0.45		0.00
8304	20	16.0	38.4	577	0	0	577	0.00		0.00
8301	18	7.0	16.8	192	0	0	192	0.00		0.00
8302	24	4.1	9.9	570	0	0	570	0.00		0.00
8305	20	17.5	42.0	1383	236	0	1619	0.49		0.00
8307	20	13.5	32.4	1664	199	0	1863	0.53	!	0.00
8306	20	1.0	2.4	148	0	0	148	0.00		0.00

Soucet	230.9	554.2	19384	2298	0	21682	
--------	-------	-------	-------	------	---	-------	--

Nadzemni podlazi

Soucet	2031.0	5684.5	112152	26493	0	138645	
--------	--------	--------	--------	-------	---	--------	--

Objekt celkem

Soucet	2099.8	5877.0	117945	27089	0	145034	
--------	--------	--------	--------	-------	---	--------	--